

Customer:

Filter Systems and Supply

Date:	09/28/00	Test Performed By:	Rick L. Chapman EFCO 805-642-2079		
Temp.	73.2 F	Product Name:	055 - Standard / Wet tack		
Humidity:	63%	Test Velocity:	200 FPM	Resistance:	.15 in. W.G.

PARTICLE SIZE (MICRON)	EFFICIENCY	Note
0.3	0.4%	
0.5	2.6%	
5	74.2%	
10	91.7%	

