

Customer:

Filter Systems and Supply

Date:	09/28/00	Test Performed By: Rick L. Chapman EFCO 805-642-2079	
Temp.	73.2 F	Product Name: 065	
Humidity:	63%	Test Velocity: 200 FPM	Resistance: .18 in. W.G.
PARTICLE SIZE (MICRON)	EFFICIENCY		Note
0.3	0.2%		
0.5	2.4%		
5	81.6%		
10	96.7%		

