

2820 S. English Station Road - Louisville, KY 40299 Tel: (502) 357-0132 Fax (502) 267-8379 Date: 11-Oct-18 TEST NO. 18-519-1 Rev2

# ASHRAE Standard 52.2-2017 TEST REPORT

Initial Efficiency / Resistance

### Filter Description


Manufacturer
Filter Model
Part Number
Generic Filter Type
Nominal Dimensions (H x W x D)
Pocket / Pleat Quantity
Media Type
Est. Gross Media Area


Adhesive Type

SWISS-FLOW Intake Pad

Filter Systems

20" x 20" x 1" N/A Synthetic 2.78 Ft<sup>2</sup> N/A





## **Test Conditions**

Loading Dust Type NA Test Air Temp (degrees F.) 74
Barometric Pressure (In. Hg.) 29.31 Relative Humidity (%) 39

#### **Test Results**

 Airflow Rate (CFM)
 278

 Nominal Face Velocity (fpm)
 100

 Initial Resistance (in WG)
 0.30

 E1 (%) Initial Efficiency 0.30 - 1.0 um
 2

 E2 (%) Initial Efficiency 1.0 - 3.0 um
 35

 E3 (%) Initial Efficiency 3.0 - 10.0 um
 97

Estimated \* Minimum Efficiency Reporting Value (MERV)

\* If initial data is minimum


MERV 9 @ 278 CFM


Comments Tested For: Filter Systems

Test Performed by: JPS Approved By: Page 1 of 3

Rev: 4 Date: 2/27/2017

Test No. 18-519-1 Rev2 Date: 11-Oct-18





Rev: 4 Date: 2/27/2017

Date:

2820 S. English Station Rd. Louisville, KY 502 357 0132

Test No. 18-519-1 Rev2

11-Oct-18

Test Report

## **Data - Initial Resistance**

Airflow	Resistance
(CFM)	(in WG)
0	0.00
70	0.07
139	0.13
209	0.21
278	0.30
348	0.39

# **Data - Particle Removal Efficiency**

	Coometrie	Initial
	Geometric	Initial
Particle Size Range	Mean Diam	Particle Removal Efficiency
(um)	(um)	(%)
0.30 - 0.40	0.35	0.4
0.40 - 0.55	0.47	0.6
0.55 - 0.70	0.62	1.5
0.70 - 1.00	0.84	6.4
1.00 - 1.30	1.14	14.5
1.30 - 1.60	1.44	23.3
1.60 - 2.20	1.88	36.7
2.20 - 3.00	2.57	64.7
3.00 - 4.00	3.46	89.4
4.00 - 5.50	4.69	98.5
5.50 - 7.00	6.20	99.8
7.00 - 10.00	8.37	99.9

Rev: 4 Date: 2/27/2017